

## **CERTIFICATE OF COMPLIANCE**

Certificate Number: SGSNA/24/SZ/00092

Contract Number: 802329

Certificate Project Number: SZ-CERT240100145

Certified Product: Rechargeable Li-ion Battery Storage System

Trademarks: Sol-Ark
Model(s): L3 HVR-60
Technical Data: 614.4Vd.c, 100Ah

307.2Vd.c, 200Ah;

Maximum charge current: 100A; Maximum discharge current: 100A; Charge operating temperature: 0 to 55 °C; Discharge operating temperature: -20 to 55 °C

Certificate Holder: Portable Solar LLC d/b/a Sol-Ark

805 Central Expwy S Allen, Texas, 75013, United States of America

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at <a href="www.sgs.com">www.sgs.com</a> or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:

ANSI/CAN/UL 1973, 2.0 Edition, Dated February, 2018

son wei

Authorized by:

Jason Wei Certifier Effective date: 06 February 2024

Page 1 of 1

SGS operates certification programs under the authority of several accreditation or recognition bodies including A2LA, ANAB, OSHA NRTL, and Standards Council of Canada. This certificate is issued by the company under its General Conditions for Certificate in Services accessible at <a href="https://www.sgs.com/en/terms-and-conditions">https://www.sgs.com/en/terms-and-conditions</a>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**Certification Body** 

Connectivity & Products, a division of SGS North America Inc. 620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

